



The Corporation of the
Township of Drummond/North Elmsley

2019-2024 Multi-Year Accessibility Plan



2021 UPDATE

DESCRIPTION	YEAR	COMPLETED
File an accessibility compliance report	2019	Completed
Website and contents must conform with WCAG 2.0 Level	2021	Completed
File an accessibility compliance report by December 31 2021	2021	
BARRIERS TO BE REMOVED		
Ferguson's Falls Hall		
<u>Hall:</u>		
Threshold lip is 1 inch - exceeds 1/2 inch	2022	
Front lip door threshold is 1 1/4 inch	2024	
Need an automatic door	2024	
Needs a lever handle on back door	2022	
<u>Bathroom</u>		
Sink is too close to the wall	2022	
Washroom signage should be at the top of the hallway	2022	
Wrong toilet seat - need an elongated toilet seat	2022	
Should install fold down grab bars - optional	2022	
Requires a hook and shelf	2022	
Longer lever handles on sink	2020	Completed
Should install an audible call button	2022	
This building is at the end of its life cycle. A new community will be constructed in the future and at that time it brought up to full accessible standards		
Municipal Office Washrooms		
Should install an audible call button	2022	
Should install fold down grab bars - optional	2022	
Need L shaped grab bar	2022	
Requires a counter/shelf	2021	Completed
Kitchen taps should be lever handles	2023	
Need a hook at reception for canes	2023	
Old washrooms need lever handles	2020	Completed
Drummond Centre Hall		
<u>Washroom:</u>		
Hand towel dispenser is too high	2023	
Need L shaped grab bar	2023	
Requires a hook and shelf in the bathroom	2021	Completed
Should install an audible call button	2024	

Rideau Ferry Public Docks

The transition from concrete to floating docks should include an extended handrail.	2021	
---	------	--

Comments:

We will be migrating to more online services in 2021. This will mean that our residents will be able to access some of our services online.

The Township is conducting Facility Condition Assessments in Fall 2021 and that will capture all accessibility issues.