



Township of Drummond/North Elmsley Outdoor Boiler Application

OFFICE USE ONLY
Permit #

Contact Information:

Name of Owner: _____

Name of Applicant: (If different than owner): _____

Site Address: _____

Owner Phone #: _____ Owner E-mail: _____

Boiler make: _____ Model: _____ Project Cost: \$ _____

Chimney make: _____ Model: _____

Name of Contractor (if applicable): _____

Contractors Phone: _____ E-mail: _____

Outdoor solid fuel combustion appliances **are not permitted** in a:

- Subdivision Limited Services Residential Zone "Hamlet" in the Township's Official Plan

Not more than one (1) outdoor boiler is permitted on a lot unless it serves an accessory dwelling or an agricultural building on lands which are used primarily for agricultural purposes.

Outdoor solid fuel combustion appliances **shall be permitted** only where:

- The property has a minimum lot area of 1.2 Ha (3 acres)
 Boiler is a minimum of 46 m (150 ft.) from all property lines
 Boiler is a minimum of 9 m (30 ft.) away from any building on the property

A minimum of a 3 m (10 ft.) perimeter around the boiler shall be a non-combustible surface of:

- Gravel Sand Concrete Pad
 Boiler chimney shall be fitted/equipped with a rain cap/spark arrester
 Fuel shall be stored a minimum of 3 m (10 ft.) from the appliance
 No outdoor solid fuel combustion appliances shall be used for the incineration of waste.

